

Sample details

Client Name:	Sister Annie
Client Ref No:	
Sample ID:	JSD/SL/209
Report No:	209
Sample Description:	ST. JOSEPH'S Community Hospital Baramulla Srinagar
Test Start Date:	2-Dec-2023
Test End Date:	3-Dec-2023
Sample Collected by:	Sample collected and provided by the customer

Test Report

Physico-Chemical Parameters

Sr. No.	Parameter	BIS Permissible Limit (mg/l)	Range of Testing as per Scope (mg/l)	Test Results (mg/l)	Test Method
1	pH	6.5 - 8.5	2 - 12	7.01	IS 3025 (Part 11)
2	Colour	15 HU	5 - 100 HU	10	IS 3025 (Part 4)
3	TDS	2000	5 - 2000	390.00	IS 3025 (Part 16)
4	Turbidity	5 (NTU)	0.1 - 1000 NTU	1.88	IS 3025 (Part 10)
5	Iron	1.0	0.075 - 5.0	0.00	IS 3025 (Part 53)
6	Chloride	1000	2 - 1000	29.99	IS 3025 (Part 32)
7	Magnesium	100	1 - 1000	11.17	IS 3025 (Part 46)
8	Sulphate	400	5 - 1000	5.97	IS 3025 (Part 24)
9	Calcium	200	2 - 1000	108.21	IS 3025 (Part 40)
10	Total Hardness	600	4 - 1000	316.00	IS 3025 (Part 21)
11	Alkalinity	600	5 - 1000	335.00	IS 3025 (Part 23)

Negative

Note: The test report and result relate to the specimen/ sample (s) of the material as delivered /received and tested in the laboratory.

• This test report shall not be reproduced in part, without the permission of this laboratory.

• Any correction invalidates this test reports.

• WQC lab always strives to provide accurate and reliable for all customers. However, it is not responsible for any financial/legal liability arising out of any errors or omissions.

*ADL: Above Detectable Limits, *BDL: Below Detectable Limits

Analysed by: *[Signature]*
(Mr/Ms:)
Designation: Chemist

Reviewed by: *[Signature]*
(Mr/Ms:)
Designation: Chemist

Authorised Signatory: *[Signature]*
(Mr/Ms:)
Designation: Chief Chemist