



7.8.F.01


TEST REPORT

PARTY CODE : S/JK/12373
 ISSUED TO : ST. JOSEPH'S COMMUNITY HOSPITAL

REPORT NO. : UK0118000221
 REF. NO. : NS

BARJANI TALAB, SMAILPUR, SAMBA (J&K) - 181133

REF. DATE : NS
 DT.RECD : 18/01/2021



SAMPLE NAME : EFFLUENT WATER (STP-OUTLET)

RESULTS OF ANALYSIS
 Reference : EP Act Standard

DESCRIPTION : One Effluent water sample from Outlet of STP was collected by us on 16/01/2021.

SAMPLING DATE : 16/01/2021

SAMPLE QTY. : 2 LTR.

S.No.	Parameters	Units	Results	Limits	Protocols
1.	pH	NA	7.48	5.5 to 9.0	IS:3025 (P-11)
2.	Total Suspended Solids	mg/L	12	100	IS:3025 (P-17)
3.	Chemical Oxygen Demand	mg/L	56	250	IS:3025 (P-58)
4.	Biochemical Oxygen Demand (for 3 days at 27°C)	mg/L	13	30	IS:3025 (P-44)
5.	Oil & Grease	mg/L	3.4	10	IS:3025 (P-39)
6.	Phosphate (as P)	mg/L	1.2	5	IS:3025 (P-31)
7.	Nitrate (as NO3)	mg/L	2.4	10	IS:3025 (P-34)

Date of performance : 18/01/2021 to 22/01/2021

NA = Not Applicable

SAMPLE COLLECTED BY US

Date of completion : 22/01/2021

--- End of Test Report ---

AUTHORISED SIGNATORY

REMARKS 1. Results listed refer only to the tested sample & applicable parameters. Endorsement of products is neither inferred nor implied. Page : 1 of 1
 2. Liability of laboratory is limited to the invoiced amount only. Any dispute arising out of this report shall be subject to Delhi jurisdiction only.
 3. This Report is not to be reproduced wholly or in part and cannot be used as an evidence in the Court of law and should not be used in any advertising media without special permission in writing.
 4. Sample shall be disposed off after issue of Test Report unless specified.
 5. A complaint register is available with the laboratory. Ashutosh Joshi